NOTES:

1. ALL IN

2. ALL PII
DIAGR
FOR F

3. CONTR
AND M.

4. THE RC
105°F.

5. ELECTR
SYSTEM

6. EQUIPM
EDITIO

7. WIRE L
REQUIF

8. ALL ACC

1. ALL INTERCONNECTING PIPE AND FITTINGS SHALL BE INSTALLED BY THE CONTRACTOR.

2. ALL PIPING SHALL BE INSTALLED IN ACCORDANCE WITH NFPA 99, 2005 EDITION. PIPING LAYOUT IS DIAGRAMMATIC ONLY. FINAL ARRANGEMENT WILL BE SITE SPECIFIC. CONTRACTOR WILL BE RESPONSIBLE FOR FIELD VERIFICATION AND COORDINATING ACTUAL LOCATION WITH ALL OTHER TRADES.


- CONTRACTOR SHALL VERIFY MOTOR VOLTAGE, PHASE AND AMP RATINGS BEFORE STARTING ELECTRICAL INSTALLATION; AND MAKE CERTAIN THE VOLTAGE SUPPLIED BY THE HOSPITAL IS THE SAME.
- THE ROOM REQUIRES DEDICATED MECHANICAL VENTILATION WITH AN ALLOWABLE TEMPERATURE VARIANCE OF 40° TO 105°F. (FOR HIGHER AMBIENTS, CONSULT FACTORY)
- ELECTRICAL POWER SHALL BE SUPPLIED FROM THE EQUIPMENT SYSTEM BRANCH OF THE ESSENTIAL ELECTRICAL SYSTEM (EMERGENCY POWER).
- EQUIPMENT, INSTALLATION, AND TESTING OF THE MEDICAL VACUUM SYSTEM SHALL COMPLY WITH NFPA 99, 2005 EDITION, AND ALL STATE AND LOCAL CODES OR ORDINANCES.
- 7. WIRE LAG PUMP RUNNING ALARM REMOTE CONTACTS IN THIS CONTROL SYSTEM TO MASTER ALARM SYSTEM AS REQUIRED BY NFPA 99.
- 8. ALL ACCESSORIES, PIPE AND FITTINGS, BEYOND INLET AND DISCHARGE PORTS ARE SUPPLIED AND INSTALLED BY OTHERS.
- 9. WHEN DETERMINING THE TOTAL PIPE LENGTH, ADD ALL THE STRAIGHT LENGTHS OF PIPE TOGETHER IN ADDITION TO THE NUMBER OF ELBOWS TIME THE THE EFFECTIVE PIPE LENGTH FOR THAT PIPE SIZE. (SEE EQUIVALENT PIPE LENGTH TABLE & EXAMPLE CALCULATION IN THE O&M MANUAL)

EXHAUST PIPE SIZE TABLE			
(SEE NOTE 9)			
UNIT SIZE	PIPE LENGTH		
QX 10	0-200'	201'-500	
	4.00" NPT	5.00" NPT	


EFFECTIVE PIPE LENGTH			
FOR ELBOWS			
PIPE SIZE (IN)	4.00" NPT	5.00" NPT	
EFF. PIPE	10	11.9	
LENGTH (FT)			

— — — FIELD PIPING INLET

= = = FIELD PIPING OUTLET



TANK DRAIN CONNECTION-



(200 GALLON RECEIVER SHOWN)

-MAIN LINE VACUUM SWITCH

-MAIN VACUUM GAGE

SOURCE SHUTOFF VALVE

-INLET 3" FLANGE

INSTALLATION DIAGRAM 10HP

TX-X-QX LUBE VAC SPC

HOP130707

FOR INTAKE PIPE SIZING REFER TO STANDARD

PRESSURE DROP TABLES. TOTAL PRESSURE

DROP SHOULD BE LESS THAN 2" Ha AT A

SYSTEM VACUUM LEVEL OF 15" Hg.

FUTURE-

PUMP

EXPANSION

FROM HOSPITAL

T

Form F-007 Rev. 01