


- ALL INTERCONNECTING PIPE AND FITTINGS SHALL BE INSTALLED BY THE CONTRACTOR.
- D 2. ALL PIPING SHALL BE INSTALLED IN ACCORDANCE WITH NFPA 99. PIPING LAYOUT IS DIAGRAMMATIC ONLY. FINAL ARRANGEMENT WILL BE SITE SPECIFIC. CONTRACTOR WILL BE RESPONSIBLE FOR FIELD VERIFICATION AND COORDINATING ACTUAL LOCATION WITH ALL OTHER TRADES.
 - 3. CONTRACTOR SHALL VERIFY MOTOR VOLTAGE, PHASE AND AMP RATINGS BEFORE STARTING ELECTRICAL INSTALLATION; AND MAKE CERTAIN THE VOLTAGE SUPPLIED BY THE HOSPITAL IS THE SAME.
 - 4. THE ROOM REQUIRES DEDICATED MECHANICAL VENTILATION WITH AN ALLOWABLE TEMPERATURE VARIANCE OF 40° TO 105°F. (FOR HIGHER AMBIENTS, CONSULT FACTORY)
- 5. ELECTRICAL POWER SHOULD BE SUPPLIED FROM THE EQUIPMENT SYSTEM BRANCH OF THE ESSENTIAL ELECTRICAL SYSTEM (EMERGENCY POWER).
- 6. EQUIPMENT, INSTALLATION, AND TESTING OF THE MEDICAL VACUUM SYSTEM SHALL COMPLY WITH NFPA 99 AND ALL STATE AND LOCAL CODES OR ORDINANCES.
- 7. WIRE LAG PUMP RUNNING ALARM REMOTE CONTACTS IN THIS CONTROL SYSTEM TO MASTER ALARM SYSTEM AS REQUIRED BY NFPA 99.
- ALL ACCESSORIES, PIPE AND FITTINGS EXCEPT DISCHARGE FLEX HOSE BEYOND INLET AND DISCHARGE PORTS ARE SUPPLIED AND INSTALLED BY OTHERS.
- 9. WHEN DETERMINING THE TOTAL PIPE LENGTH, ADD ALL THE STRAIGHT LENGTHS OF PIPE TOGETHER IN ADDITION TO THE NUMBER OF ELBOWS TIME THE EFFECTIVE PIPE LENGTH FOR THAT PIPE SIZE. (SEE EQUIVALENT PIPE LENGTH TABLE & EXAMPLE CALCULATION IN THE O&M MANUAL)



 FIELD PIPING INLET ==== FIELD PIPING OUTLET EXHAUST PIPE SIZE TABLE (SEE NOTE 9) UNIT SIZE 151' - 400' 0' - 150' 1.00" NPT DPX 1.5 HP 1.25" NPT **UNIT SIZE** 0' - 50' 51' - 200' DPX 2 HP 1.00" NPT 1.25" NPT NO VIBRATION PADS ARE **NECESSARY AT THIS LOCATION** EFFECTIVE PIPE LENGTH TABLE FOR ELBOWS 1.0" NPT 1.25" NPT 1.5" NPT 2.0" NPT PIPE SIZE (IN)





-RECEIVER MANUAL DRAIN 1/2" NPT, CONTRACTOR TO PIPE TO NEAREST FLOOR DRAIN

NO FOUNDATION OR INERTIA PAD IS REQUIRED (HOUSEKEEPING PAD IS OPTIONAL)

-HOSPITAL INLET CONNECTION 1-1/2" NPT

BEACONMEDÆ 4107 8554 18 INSTALLATION DIAGRAM DX HOP150333 1.5-2HP DRY VTM V 30G TAE Sheet 1 of 1

(2 HP WITH 30 GALLON RECEIVER SHOWN)

EFFECTIVE PIPE LENGTH (FT) 3 3.4 4.0 4.9